

Product Information D3**FOOD**

D3 Differential Pressure & Level Transmitter


Range of applications

- Level in pressurized vessels with continuous process temperatures up to 110°C (230°F)
- CIP/SIP at 135°C (275°F) for 1 hour when ambient is below 60°C (140°F)
- Differential pressure measurement across filters

Application examples

- Level monitoring in yogurt culture vessels
- Level monitoring in fermentation vessels
- Grain bed monitoring in lauter tuns
- Level monitoring in brite tanks
- Pressure drop measurement across filters

Hygienic design/Process connection

- Front flush, 3-A installation for silos by Anderson flush fitting, E&H universal, or tank spud connections
- Conforming to 3-A Sanitary Standard 74-06 with Tri-Clamp® DIRECTadapt
- Product contacting materials compliant to FDA
- Sensor and product contact surfaces made of stainless steel
- Available with over 20 integral hygienic connections, more available through CLEANadapt adapters

Features

- Intuitive user interface makes set-up and configuration easy
- Electronic Differential provides 2 analog outputs (differential pressure and top or bottom pressure)
- State of the art temperature compensation minimizes error in dynamic temperature applications
- Fully electronic differential allows field replacement of components and repairability.
- Integrated tank tables allows volume and mass output when tank and product information are input
- Available in relative (vacuum and pressure)
- Patented dual o-ring seals provide IP69K ingress protection
- Dual loop output with Hart 7.0 communication and graphical LCD display

Options/Accessories

- Optional digital remote kit making display easier to view
- Optional M12 molded cordset available
- Wide range of ranges and fittings available

Measuring principle of the pressure sensor

In the D3 system each sensor uses a piezoresistive transducer to measure the difference between the atmospheric and process pressures. Additionally, a temperature sensor measures the temperature of the transducer and fill fluid to provide an output compensation. The resistive temperature signal and the voltage signal from the transducer are inputs to a correction algorithm which provides a pressure output in digital form. The digital signal is transferred from each sensor to the head where the microprocessor determines the difference and converts the output to a 4-20mA signal for the difference and one for the head pressure or total system pressure depending on the user's selection.

Authorizations**Differential level sensor D3****Differential level sensor D3**

| Specification | | |
|-------------------------------|--------------------------------|--|
| Measuring range URL | Relative | -14.7...500 PSI, -1...35 BAR, -400...13850 inches of w.c. |
| Overpressure strength | Factor | 1.5 x nominal pressure of measuring element |
| Measurement accuracy | Differential (PV) error | +/- 0.15% (DIFF _{URV} +TOP _{URV}) |
| | Top/Bottom sensor (SV) error | +/-0.10% of calibrated range up to 5:1 turndown (+/-0.15% if over 5:1 turndown) |
| | Repeatability | 0.05 % |
| | Long-term stability | 0.2 % URL every 2 years |
| Temperature effect | Process | < 0.016 % of calibrated measuring range / 5.5 °C (10 °F) |
| | Ambient | < 0.016 % of calibrated measuring range / 5.5 °C (10 °F) |
| Temperature range | Process | -18...110 °C (0...230 °F), at ambient ≤ 71 °C (160 °F) |
| | Ambient | -18...71 °C (0...160 °F) |
| | CIP/SIP Cleaning | 135 °C (275 °F) for 1 hour when ambient is below 60 °C (140 °F) |
| Response time | | < 0.2 seconds |
| Sample rate | | < 0.05 seconds |
| Materials | Connection head | Stainless steel, AISI 304 (1.4301), R _a ≤ 0.8 μm (32 microinch) |
| | Metal cover | Stainless steel, AISI 304 (1.4301), R _a ≤ 0.8 μm (32 microinch) |
| | Plastic cover | Polycarbonate |
| | Threaded connector | Stainless steel, AISI 304 (1.4301), R _a ≤ 0.8 μm (32 microinch) |
| | Wetted parts | Stainless steel, AISI 316L, R _a ≤ 0.64 μm (25 microinch) |
| | Diaphragm | Stainless steel, AISI 316L, R _a ≤ 0.64 μm (25 microinch) |
| | Diaphragm seal/oil filling | Medical white oil / mineral oil / paraffin oil FDA approval number 21CFR172.878, 21CFR178.3620, 21CFR573.680 Neobee M20 (optional) |
| | | |
| Process connection | 3-A compliant | 1.5", 2", 2.5", 3" Tri-Clamp® AIC CPM Flush Mount Anderson Flush Mount - Short and Long King Gage Flush Mount - Short, Medium and Long Rosemount/Foxboro Sanitary Spud - Short and Long Endress & Hauser Universal Adaptor - Short and Long |
| | not 3-A compliant | G1" CLEANadapt 1.5" NPT G1" Fixed Thread 38mm, 51mm SMS Liner (female) 40mm, 50mm DIN 11851 (Milk Coupling) M38x1.5 DRD |
| Electric connection | Cable gland | M16x1.5 |
| | Plug-in connection | M12 plug, 5-pin, 1.4305 |
| Approvals | | 3A CE Compliant CRN#OF19809.5 (consult factory for applicable regions and configurations) CAN/CSA-22.2 No. 61010-1 IP 69 K (with plug-in M12 connection) IP 67 (with cable gland) / NEMA 4X |
| Auxiliary Power Supply | Voltage | 18...35 V DC |
| | Current Limit | 4.2A |
| Output | Loop 1 (Differential) | analog 4...20 mA and Hart 7.0 |
| | Loop 2 (Top or Bottom) | analog 4...20 mA |
| Tightening torque | For assembly all D3 components | 27 Nm (20 ft-lbs) |

Cleaning/Maintenance

- In case of using pressure washers, don't point nozzle directly to electrical connections!

Reshipment

- Sensors shall be clean and must not be contaminated with dangerous media! Note the advice for cleaning!
- Use suitable transport packaging only to avoid damage of the equipment!

Advice to conformity

- Applicable guidelines:
Electromagnetic compatibility 2004/108/EC
- The accordance with applicable EC-guidelines is confirmed with CE-labeling of the device.
- You have to guarantee the compliance of all guidelines applicable for the entire equipment.

Transport/Storage

- No outdoor storage
- Dry and dust free
- Not exposed to corrosive media
- Protected against solar radiation
- Avoiding mechanical shock and vibration
- Storage temperature -55...+90 °C
- Relative humidity max. 95 %

Standards and guidelines

- You have to comply with applicable regulations and directives.

Disposal

- This instrument is not subject to the WEEE directive 2002/96/EC and the respective national laws.
- Pass the instrument directly on to a specialised recycling company and do not use the municipal collecting points.

Order code of fully assembled sensor

D3 Sensor assembled

Capillary fill

- 1** Mineral Oil (FDA approved)
- 5** Neobee M20

Top Sensor URL

- 5** 0...6 PSI, 0...0.4 BAR, 0...166" w.c.
- 6** -14.7...30 PSI, -1...2 BAR, -400...830" w.c.
- 7** -14.7...100 PSI, -1...7 BAR, -400...2770" w.c.
- 8** -14.7...500 PSI, -1...35 BAR, -400...13850" w.c.

Top Sensor Fitting

XXX (See fittings table for 3 digit code)

Top Sensor Remote Cable

- 0** Integral
- B** 10' Cable
- E** 25' Cable
- F** 50' Cable

Bottom Sensor URL

- 5** 0...6 PSI, 0...0.4 BAR, 0...166" w.c.
- 6** -14.7...30 PSI, -1...2 BAR, -400...830" w.c.
- 7** -14.7...100 PSI, -1...7 BAR, -400...2770" w.c.
- 8** -14.7...500 PSI, -1...35 BAR, -400...13850" w.c.

Bottom Sensor Fitting

XXX (See fittings table for 3 digit code)

Bottom Sensor Remote Cable

- 0** Integral
- B** 10' Cable
- E** 25' Cable
- F** 50' Cable

Enclosure cap

- 2** Clear cap
- 3** Stainless steel cap

Connector Locations

| | Electric | Top Sensor | Bottom Sensor |
|----------|----------|------------|---------------|
| 1 | A | B | C |
| 2 | A | C | B |
| 3 | B | A | C |
| 4 | B | C | A |
| 5 | C | A | B |
| 6 | C | B | A |

Electrical connection

- A** M12 QDR
- C** Cable gland
- N** 1/2" NPTF adaptor

Top Pressure Unit

- P** PSI
- B** BAR
- W** inches of water
- L** millibar

Top Pressure Range


XXX See "Calibrated Range" table

Differential Output Unit

- P** PSI
- B** BAR
- W** inches of water
- L** millibar

Differential Output Range

XXX See "Calibrated Range" table



D3 1 6 005 A 6 005 A 2 1 A P 060 W 294

| Calibration range inches w.c. | | |
|-------------------------------|----------|----------|
| Code | Range | Stem URL |
| 502 | 0...18 | 5 |
| 065 | 0...20 | 5 |
| 066 | 0...30 | 5 |
| 224 | 0...35 | 5 |
| 067 | 0...40 | 5 |
| 068 | 0...50 | 5 |
| 069 | 0...60 | 5 |
| 206 | 0...70 | 5 |
| 071 | 0...100 | 5, 6 |
| 294 | 0...140 | 5, 6 |
| 073 | 0...150 | 5, 6 |
| 074 | 0...160 | 5, 6 |
| 075 | 0...200 | 6 |
| 077 | 0...300 | 6, 7 |
| 078 | 0...350 | 6, 7 |
| 079 | 0...400 | 6, 7 |
| 503 | 0...415 | 6, 7 |
| 504 | 0...480 | 6, 7 |
| 081 | 0...500 | 6, 7 |
| 505 | 0...830 | 6, 7 |
| 084 | 0...1000 | 7 |
| 499 | 0...1200 | 7 |
| 506 | 0...1385 | 7, 8 |
| 507 | 0...1600 | 7, 8 |
| 086 | 0...2000 | 7, 8 |
| 508 | 0...3300 | 8 |
| 089 | 0...4000 | 8 |

| Calibration range PSI | | |
|-----------------------|-------------|----------|
| Code | Range | Stem URL |
| 025 | -14.7...0 | 6 |
| 028 | -14.7...15 | 6, 7 |
| 029 | -14.7...30 | 6, 7 |
| 031 | -14.7...60 | 7, 8 |
| 032 | -14.7...100 | 7, 8 |
| 314 | -14.7...200 | 8 |
| 501 | 0...1.2 | 5 |
| 428 | 0...1.5 | 5 |
| 057 | 0...2 | 5 |
| 235 | 0...3 | 5, 6 |
| 192 | 0...4 | 5, 6 |
| 060 | 0...6 | 5, 6 |
| 309 | 0...7 | 6 |
| 061 | 0...10 | 6, 7 |
| 502 | 0...18 | 6, 7 |
| 065 | 0...20 | 6, 7 |
| 066 | 0...30 | 6, 7 |
| 224 | 0...35 | 7 |
| 067 | 0...40 | 7 |
| 068 | 0...50 | 7, 8 |
| 069 | 0...60 | 7, 8 |
| 206 | 0...70 | 7, 8 |
| 071 | 0...100 | 7, 8 |
| 294 | 0...140 | 8 |
| 073 | 0...150 | 8 |
| 074 | 0...160 | 8 |
| 075 | 0...200 | 8 |
| 077 | 0...300 | 8 |
| 078 | 0...350 | 8 |
| 079 | 0...400 | 8 |
| 503 | 0...415 | 8 |
| 504 | 0...480 | 8 |
| 081 | 0...500 | 8 |

| Calibration range BAR | | |
|-----------------------|----------|----------|
| Code | Range | Stem URL |
| 251 | -1...1 | 6, 7 |
| 286 | -1...2.5 | 7 |
| 217 | -1...3 | 7 |
| 056 | -1...4 | 7, 8 |
| 304 | -1...7 | 7, 8 |
| 501 | 0...1.2 | 6, 7 |
| 428 | 0...1.5 | 6, 7 |
| 057 | 0...2 | 6, 7 |
| 235 | 0...3 | 7 |
| 192 | 0...4 | 7, 8 |
| 060 | 0...6 | 7, 8 |
| 309 | 0...7 | 7, 8 |
| 061 | 0...10 | 8 |
| 502 | 0...18 | 8 |
| 065 | 0...20 | 8 |
| 066 | 0...30 | 8 |
| 224 | 0...35 | 8 |

| Calibration range mBAR | | |
|------------------------|----------|----------|
| Code | Range | Stem URL |
| 224 | 0...35 | 5 |
| 067 | 0...40 | 5 |
| 068 | 0...50 | 5 |
| 069 | 0...60 | 5 |
| 206 | 0...70 | 5 |
| 071 | 0...100 | 5 |
| 294 | 0...140 | 5 |
| 073 | 0...150 | 5 |
| 074 | 0...160 | 5 |
| 075 | 0...200 | 5, 6 |
| 077 | 0...300 | 5, 6 |
| 078 | 0...350 | 5, 6 |
| 079 | 0...400 | 5, 6 |
| 503 | 0...415 | 5, 6 |
| 504 | 0...480 | 6 |
| 081 | 0...500 | 6 |
| 505 | 0...830 | 6, 7 |
| 084 | 0...1000 | 6, 7 |
| 499 | 0...1200 | 6, 7 |
| 506 | 0...1385 | 6, 7 |
| 507 | 0...1600 | 6, 7 |
| 086 | 0...2000 | 6, 7 |
| 508 | 0...3300 | 7 |
| 089 | 0...4000 | 7, 8 |

Note:

When multiple stem URLs are available (**Example 5,6**), lower stem URL is recommended (**Select 5**).

Order code of sensor stem

L3S (Sensor stem)

URL

5 0...6 PSI, 0...0.4 BAR, 0...166" w.c.
6 -14.7...30 PSI, -1...2 BAR, -400...830" w.c.
7 -14.7...100 PSI, -1...7 BAR, -400...2770" w.c.
8 -14.7...500 PSI, -1...35 BAR, -400...13850" w.c.

Fitting (See Fittings Table)

XXX

Capillary fill

1 Mineral Oil (FDA approved)
5 Neobee M20

Remote cable

O Integral
B 10' Cable
E 25' Cable
F 50' Cable

L3S 6 005 1 0

Fittings Table

3-A compliant fittings

- 004** 1.5" Tri-Clamp®
- 005** 2" Tri-Clamp®
- 006** 2.5" Tri-Clamp®
- 007** 3" Tri-Clamp®
- 123** AIC CPM Flush Mount
- 088** Anderson Flush Mount Short (71060-A4, A6)
- 089** Anderson Flush Mount Long (71060-A3, A5, A9)
- 092** King Gage Flush Mount Long (1773-3)
- 093** King Gage Flush Mount Medium (1773-1, -6 Std.)
- 094** King Gage Flush Mount Short (1773-2)
- 141** Rosemount/Foxboro Sanitary Spud - Short
- 142** Rosemount/Foxboro Sanitary Spud - Long
- 154** Endress & Hauser Universal Adaptor - Short
- 155** Endress & Hauser Universal Adaptor - Long

Fittings not 3-A compliant

- 160** G1" CLEANadapt
- 059** 1.5" NPT
- 182** G1" Fixed Thread
- 109** 38 mm SMS Liner (female)
- 110** 51 mm SMS Liner (female)
- 115** 40 mm DIN 11851 (Milk Coupling)
- 124** 50 mm DIN 11851 (Milk Coupling)
- 180** M38x1.5
- 181** DRD

Order code of sensor head

D3E

Enclosure cap

2 Clear cap
3 Stainless steel cap

Connector Locations

| | Electric | Top Sensor | Bottom Sensor |
|----------|----------|------------|---------------|
| 1 | A | B | C |
| 2 | A | C | B |
| 3 | B | A | C |
| 4 | B | C | A |
| 5 | C | A | B |
| 6 | C | B | A |

Electrical connection

A M12 QDR
C Cable gland
N 1/2" NPT adaptor

Top Pressure Unit

P PSI
B BAR
W inches of water
L millibar

Top Pressure Range

XXX See "Calibrated Range" table


Differential Output Unit

P PSI
B BAR
W inches of water
L millibar

Differential Output Range

XXX See "Calibrated Range" table

D3E 2 1 A P 060 W 294



Cord Sets

| | |
|------------------------------|------------|
| Shielded Molded w/25' cable | 42117H0025 |
| Shielded Molded w/50' cable | 42117H0050 |
| Shielded Molded w/100' cable | 42117H0100 |

Weld-In Shells for Anderson Flush Mount (316L)

| | |
|---|------------|
| Anderson Long - Insulated Standard Vessel | 71060A0003 |
| Anderson Short - Uninsulated Standar Vessel | 71060A0004 |
| Anderson Long - Insulated Pressure Vessel | 71060A0005 |
| Anderson Short - Uninsulated Pressure Vessel | 71060A0006 |
| Anderson Long - Insulated H/D Pressure Vessel | 71060A0009 |

Tank Shell Plugs (Supplied with nut and gasket)

| | |
|----------------------|------------|
| Anderson Long | 56511B0001 |
| Anderson Short | 56511B0002 |
| Cherry Burrell Long | 56511A0001 |
| Cherry Burrell Short | 56511A0002 |
| King Long | 56511C0001 |
| King Medium | 56511C0002 |
| King Short | 56511C0003 |

Flush Mount Calibration Adapters

| | |
|------------------------|------------|
| Anderson Fitting | 73198A0001 |
| Cherry Burrell Fitting | 73198A0002 |
| King Gage Fitting | 73198A0003 |

Gaskets for Flush Mount Fittings

| | |
|------------------------------------|------------|
| Anderson - Silicone | 44348A0001 |
| Anderson - Silicone (USP Class VI) | 44348A0003 |
| Cherry Burrell - Silicone | 44292A0001 |
| Endress & Hauser - Silicone | 45352A0001 |
| King Gage - Silicone O-Ring | 36240S3212 |
| Rosemount - Silicone O-Ring | 36240S3341 |

Other Accessories

| | |
|------------------------------------|--------------|
| Clear Cap w/gaskets | 5632800001 |
| Stainless Steel Cap w/gaskets | 5632900001 |
| M12 Quick Disconnect Receptacle | SP56726A0004 |
| Cord Grip | SP5633100000 |
| 1/2" NPTF adaptor | SP5633200000 |
| Seal Kit (6) gaskets | 5633000001 |
| Field Wireable Connector-Straight | 42119B0000 |
| Field Wireable Connector-90° | 42119A0000 |
| 10' Remote Kit | SP73228A0010 |
| 25' Remote Kit | SP73228A0025 |
| 50' Remote Kit | SP73228A0050 |
| Rosemount/Foxboro Clamp Connection | 46600A00010 |

